

राष्ट्रीय प्रौद्योगिकी संस्थान रायपुर
(राष्ट्रीय महत्त्व का संस्थान)



National Institute of Technology Raipur
(An Institution of National Importance)

Annexure (6)

Testing and Consultancy Cell — Department of Civil Engineering

No. NITRR CIVIL/2013 / 5963 Raipur,

Dated: 06-05-2013.

To,

Mile Stone Academy
Kohka, Junwani Road,
Bhilai - Chhattisgarh

Subject: Checking of Drawings & Design of School Building at Khapri Durg

Reference: 1. Your office letter No.: Nil , Dated 02-05-2013.

Please find herewith Proof Checked copy of Structural Drawings for School Building at Khapri.


The Structural Design and Drawings have been checked for the following parameters.

1. Safe Bearing Capacity of Soils 30 T/m².
2. G+2 Construction.
3. Dead load & Live load only. These loads are as per IS:875 Part I & II.
4. M-20 grade of Concrete and Fe 415 grade of steel.
5. Very good quality control on Material and Construction

Design and Drawings Checked by

Saxena
6.5.13

Dr. Rajesh Tripathi
Professor in Civil Engineering



Forwarded by

Saxena

Head of the Department (Civil Engineering)
National Institute of Technology Raipur
RAIPUR- 492010 (C.G.)

Mile Stone Academy

Saxena
Principal

Mile Stone Academy

Saxena
Principal